Łukasiewicz
Institute
of Ceramics
and Building
Materials

Łukasiewicz Research Network – Institute of Ceramics and Building Materials
31-983 Kraków, Cementowa 8 Str., Poland

CENTER OF CERAMICS AND CONCRETE

02-676 Warszawa
Postepu 9 Str., Poland
phone: +48 601 362 348

03-046 Warszawa
Kupiecka 4 Str., Poland
phone: +48 731 731 446

agnieszka.ducka@icimb.lukasiewicz.gov.pl
katarzyna.laskawiec@icimb.lukasiewicz.gov.pl

RESEARCH LABORATORY

www.lclmb.lukasiewicz.gov.pl

PCA
Polskie Centrum Akredytacji
BADANIA
AB 054

TEST REPORT NO 119/P/LB/2022(EN)

SUBJECT OF TESTING: CERAMIC TILES

ORDERER: CERAMIKA KOŃSKIE Sp. z o.o.
ul. Ceramiczna 5
26-200 Końskie

DATE OF RECEIPT THE SAMPLES: 21.07.2022 r.

DATE OF TESTS: 02.08 – 05.08.2022

EXECUTOR: M.Sc. Eng Marcin Pożarowszczyk
Technician Jacek Kamiński

Number of copies: 1

Number of pages: 3

Warsaw, 24.08.2022

1. Subject of testing

Sample of the glazed dry-pressed ceramic tiles of the following type:

- LIVERPOOL 15,5 x 62 cm

Producer: CERAMIKA KOŃSKIE Sp. z o.o.
ul. Ceramiczna 5
26-200 Końskie

Number of sample: 12 pieces
Designation of sample: 108P/2022
The samples taken and delivered to the Research Laboratory by the Orderer.

2. Scope of tests and the place of their execution.

– determination of critical slip angle

Scope of tests has been established by the Customer.
Tests have been made in the Research Laboratory Research Group Ceramic, CCiB, ul. Kupiecka 4, 03-046 Warszawa.

3.Testing methods:

DIN 51130:2014–02	Testing of floor coverings. Determination of the anti-slip properties. Workrooms and fields of activities with slip danger, walking method. Ramp test.

4. Results of tests

4.1. Determination of critical slip angle.

According to DIN 51130:2014–02 Testing of floor coverings. Determination of the anti-slip properties. Workrooms and fields of activities with slip danger, walking method. Ramp test

Sample size: 0,5 m^2

Critical slip angle	
Adjusted average overall acceptable angle α_{ges}	Anti-slip properties class
7,5	R 9

5.0. Statement.

5.1. Results of tests relate exclusively to tested objects.
5.2. Test report may be copied only as a whole, whereas for partial coping the consent of laboratory is required.

The person responsible for the report:

Agnieszka Ducka, M Sc

The person authorizing the report:

Z-ca Lidera Grupy Badawczej
Ceramika
mgr Agnieszka Ducka